

TECHNIGAS

CERTIFICATE

CE/0461/EG1208/5123

Technigas, since 18 July 1996 agreed by the Ministry of Economic Affairs as body responsible for carrying out the procedures referred to in Article 7 of the Council Directive 92/42/EEC, attests that the following Low- Temperature boilers.

GB GANZ

GTE 8 star- 9 star- 10 star- 12 star- 15 star- 20 star- 25 star- 30 star- 35 star- 40 star
GTE 15 S star- 20 S star- 25 S star- 30 S star- 35 S star- 40 S star

of the company :

GB GANZ

Olasz-Magyar Tuezelestechnikai Tarasasag
HU-1103 BUDAPEST Szlavay u.22-30


comply(ies) with the efficiency requirements of the Article 5 § 1 of the Council Directive 92/42/EEC of 21 May 1992 on efficiency requirements for new hot-water boilers fired with liquid or gaseous fuels.

Appliance type: B23

The gas-fired heating boilers may be fitted with any forced draught burner which is CE-marked following the EN 676, if the operating characteristics of the boilers related to the rated heat input and the back-pressure in the combustion chamber are situated within the burner's working range.

Energie performance label : ★★★

Made in Brussels, 21/09/2007



K. DE WIT
DIRECTOR

